675 N. Causeway Blvd. Mandeville, LA 70448 (985) 629-2082 Phone (985) 629-2110 Fax

## HOSE AND PIPELINE TESTS

VESSEL:	FMT 3178
F	© ⊌
THE FOLLOWING ITEMS HAVE BEEN CHECKED AND TESTED IN ACCORDANCE WITH 46CFR 35.35-70 AND 33CFR 156.170 ON	
	X − 00
	PRESSURE GAUGES HAVE BEEN CHECKED WITHIN 10% OF ACCURACY.
	EMERGENCY SHUTDOWN HAS BEEN CHECKED AND FOUND OPERABLE.
	TRASFER SYSTEM RELIEF VALVE HAS BEEN TESTED AND CHECKED - 125 P.S.I.
	ALL TRANSFER PIPING SYSTEMS AND ASSOCIATED VALVES HAVE BEEN TESTED
N/A	AND CHECKED AT 187.5 P.S.I.  CARGO HOSE VISUALLY AND HYDROSTATICALLY CHECKED TO 225 P.S.I.
	* ** The state of
S	e <sub>e</sub> e
THE ABOVE ITEMS CHECKED, TEST	ED AND VERIFIED BY:
	Dil Me h